


TEST CERTIFICATE

| | | |
|---|--|--|
| IAF - Radioökologie GmbH | | |
| Laboratory for radionuclide analysis Radiological expertise Consulting | | |
| Determination of the radon diffusion coefficient and the diffusion length of a four-bar seal made of PVC | | |
| Client: | KRASO GmbH & Co. KG Baumannweg 1 46414 Rhede | |
| Project name: | Determination of the radon diffusion coefficient and the diffusion length of a four-bar seal made of PVC | |
| Project number: | 210416-01 | |
| Contractor: | IAF-Radioökologie GmbH | |
| Author: | Dipl.-Ing. (BA) R. Baumert | |
|  German Accreditation Body D-PL-11201-01-00 The accreditation is valid for the results shown of the determination of the radon diffusion constant of sealing materials (SOP 4.02, 2018-11). The evaluations contained in the report are based on these results. | | |
| Radeberg, 16/04/2021 | | |
| [Signature] Dr. rer. nat. habil. Hartmut Schulz Managing Director | | |
| Wilhelm-Rönsch-Str. 9 D-01454 Radeberg Tel +49 (0) 3528 48730-0 Fax +49 (0) 3528 48730-22 Email info@iaf-dresden.de | Managing Director: Dr. rer. nat. habil. Hartmut Schulz Dr. rer. nat. Christian Kunze Dipl.-Ing (BA) René Baumert Register of Companies: HRB 9185 Dresden District Court | Bank account HypoVereinsbank Dresden IBAN DE92 8502 0086 5360 1794 29 SWIFT (BIC) HYVEDEMM496 |
| certified as true translation of the original PTS GmbH 1A, rue de la Laiterie L-9910 Troisvierges www.pts.lu CR 26.03.25 | | |

TEST CERTIFICATE

TEST CERTIFICATE

IAF - Radioökologie GmbH

Labor für Radionuklidanalytik
 Radiologische Gutachten
 Consulting

Determination of the radon diffusion coefficient and the diffusion length of a four-bar seal made of PVC

1 Task

According to the order placed by KRASO GmbH & Co. KG, IAF-Radioökologie GmbH (IAF) is to determine the radon diffusion constant of a four-bar seal made of PVC and to carry out an assessment with regard to radon tightness.

2 Measuring method

To determine the radon diffusion constants, the sealing insert was installed in a 2-chamber measuring system in such a way that radon can only migrate from chamber 1 into chamber 2 if it traverses the sealing system as a result of a diffusion process. The developing radon concentration in chamber 2 is recorded in 1-hour intervals using a radon monitor. The increase in radon concentration in chamber 2 varies depending on the radon tightness of the sealing system. This results in a plateau value, which represents a dynamic equilibrium between radon migration from the radon reservoir (chamber 1) through the sealing system and radon decay in the measuring chamber (chamber 2) and determines the radon diffusion constant D, measured in [m²/s]. The diffusion length L_D of the test element is given by

$$L_D = \sqrt{\frac{D}{\lambda_{Rn}}}$$

where $\lambda_{Rn} = 2.1 \cdot 10^{-6} / s$ is the radon decay constant.

The diffusion length L_D is a measure of the average distance a radon atom penetrates through the tested element during its half-life. A sealing system is considered "radon-proof" if the thickness (d) of the material is at least 3 times its radon diffusion length (L_D)

$$R = \frac{d}{L_D} \geq 3$$

otherwise the sealing system is to be designated as "not radon-proof".

3 Measurement results and evaluation

The diffusion length as calculated from the measurement results and the result of the radon tightness test are summarised in Table 1.

Table 1: Result of the performed radon tightness test

| Sealing material | Material thickness of the specimen [d] | Diffusion constant [D] | Diffusion length [L _D] | Test parameters R = d/L _D | Assessment |
|---------------------------|--|---|------------------------------------|--------------------------------------|------------------------------|
| Four-bar seal made of PVC | 50 mm | < 1.6-10 ⁻¹⁰ m ² /s | < 8.3 mm | > 6 | R > 3, radon tight |

**certified as true translation
of the original**
PTS GmbH
 1A, rue de la Laiterie
 L-9910 Troisvierges
www.pts.lu

CP
 26.03.25