

TEST CERTIFICATE

University of Stuttgart
Materials Testing Institute
PO box 801140 • 70511 Stuttgart



Documentation of results for testing a hose adapter

Report no.: 903 2404 001

Client: Krasemann GmbH & Co. KG
Max-Planck-Str. 2
D-46414 Rhede

Order no. (client):

Order no. (MPA): 903 2404 000 /Hh/Os/Scr

Test object: KRASO[®] hose adapter including hose connector

Test specification with issue date: Bubble test

Date of receipt of the test object: 3 August 2016

Test date: 3 to 5 August 2016

Report date: 9 August 2016

Page 1 of 3 pages of text

Supplements: 1

Appendices: -

Total number of pages: 4

Number of copies: 1 x Krasemann GmbH & Co. KG

**certified as true translation
of the original**
PTS GmbH
1A, rue de la Laiterie
L-9910 Troisvierges
www.pts.lu

CR
26.03.25

The test results relate exclusively to the test specimens.

Publication of this report (also of extracts) is permitted only with the written consent of the Materials Testing Institute of the University of Stuttgart.

TEST CERTIFICATE

University of Stuttgart Materials
Testing Institute

Report no.: **903 2404 001**
Page 2 of 3 pages of text

1 Task

The test object is a **KRASO® hose adapter including hose connector** pre-installed by the client (Figure 1, Attachment 1). This was to be examined with regard to leakage. Due to the fact that soft components are involved, which react to pressure changes with a change in volume, the familiar procedures such as pressure drop, pressure increase and differential pressure methods are not used as evidence methods, even though these could be used for qualitative, but not quantitative, statements regarding the leakage rate. The vacuum or sniffer method fails because the helium leakage, due to the relatively thin material, would take place over the entire surface and not only over the connection points.

This ultimately only left the bubble test.

2 Examinations carried out

The test object is put into an enclosing tube together with two sealing inserts (Figure 2, Attachment 1) and clamped there. A valve, which is attached to the tube on the outside, can be used to apply the test pressure with compressed air. The test pressure therefore takes effect on the test object from the outside. The leakage can escape inside in the form of bubbles and be evidenced by means of visual inspection.

It was able to be established that no visible leakage occurred in the form of bubbles, either at the sealing inserts or at the valve.

3 Test results

At a test pressure of 2.5 bar, only occasional bubbles were able to be observed at an interval of approx. 3 minutes. The bubbles had a volume of approx. 1 mm³ (estimated).

The leakage rate is therefore 1·10⁻³ ml/180 s. That equates to an absolute leakage rate of approx. 6·10⁻⁶ ml/s and a specific leakage rate of approx. 1,3·10⁻⁵ ml/(s·m) (all figures are conservatively rounded).

4 Summary

A pre-installed **KRASO® hose adapter including hose connector** was examined for leakage according to the bubble test principle.

University of Stuttgart
Materials Testing Institute
Pfaffenwaldring 32
70569 Stuttgart (Vaihingen)
VAT ID no. DE 147794196

Phone: (0711) 685 – 0
Fax: (0711) 685- 62635
Website: www.mpa.uni-stuttgart.de

BW-Bank Stuttgart / LBBW
Account no. 7 871 521 687 Sort code 600 501 01
IBAN: DE51 6005 0101 7871 5216 87
BIC/SWIFT Code: SOLADESTXXX

CR
26.03.25

certified as true translation
of the original
PTS GmbH
1A, rue de la Laiterie
L-9910 Troisvierges
www.pts.lu

TEST CERTIFICATE

University of Stuttgart
Materials Testing Institute

Report no.: **903 2404 001**
Page 3 of 3 pages of text

5 Interpretation of the result and recommendations

The size of the bubbles and the time interval are merely estimated. Nevertheless, the tested hose adapter can be attributed a high leak tightness, which ought to be close to the high-quality level according to TA Luft. As this measurement method cannot be used as evidence of the high quality according to TA Luft without elaborate validation, no attempt was made to carry out more accurate evaluations.

[Stamp]

[Signature]

Werner Ottens
Experimental stress analysis department

[Signature]

Dipl.-Ing Rolf Hahn
Materials for extreme conditions department


certified as true translation
of the original
PTS GmbH
1A, rue de la Laiterie
L-9910 Troisvierges
www.pts.lu

CR
26.03.25

TEST CERTIFICATE


University of Stuttgart
Materials Testing Institute

Report no.: **903 2404 001**
Enclosure 1



[Stamp]

Fig. 1: Test object: Hose adapter with hose connector



[Stamp]

Fig. 2: Hose adapter and hose connector in installed state with sealing inserts

certified as true translation
of the original
PTS GmbH
1A, rue de la Laiterie
L-9910 Troisvierges
www.pts.lu

CR
26.03.25